

## Amendment no.: 01

Ref. No.: APSC/PRO-25/Sub-Station/2021/646


Date: 09/05/2021

**Name of the tender:** Supply, Installation, Testing & Commissioning of 03 Phase 50Hz, 100/150MVA (ONAN/ONAF), 240/140/33 KV Auto Transformer equipped with OLTC (1630A, 245 KV) for Sub-Station Division of APSC. [Ref. IFT NO.: APSC/PRO-01/2021/413; DATE: 25/03/2021

Sl. / No.	Item no. (In Form PG4-4 & Technical Specifications)	Description of Items	Existing as in tender document	Amended as in tender document
01	20.1	Impedance voltage at 75 °C and Continuous Maximum rating (CMR) between HV and LV windings		
	(a)	At extreme minus tap:	13.8%	13.8%
		Normal tap:	<b>16.6%</b>	<b>17.2%</b>
		Extreme plus tap:	26.4%	26.4%
02	20.2	Impedance voltage at 75 °C and CMR between HV and LV windings at normal tap	<b>16.60%</b>	<b>17.2%</b>
03	89	Parallel Operation	Transformer will be used in parallel operation with existing Autotransformer (100/150 MVA, 240/140/33 kV, Vector group: YNa0+d1, and impedance voltage at nominal tap= <b>16.6%</b> .	Transformer will be used in parallel operation with existing Autotransformer (100/150 MVA, 240/140/33 kV, Vector group: YNa0+d1, and impedance voltage at nominal tap= <b>17.2%</b>




N.B.: The tenderers are requested to complete as per above-mentioned amended serial number in the columns of the Specifications Submission and Compliance Sheet (Form PG4-4) and this amendment is also applicable for Section: 07 Technical Specifications of tender document.



09.05.21

**(Biazid Bostame)**

Assistant Manager (Procurement)  
Ashuganj Power Station Company Ltd.  
(An enterprise of Bangladesh Power  
Development Board)  
Ashuganj, Brahmanbaria, Bangladesh.  
E-mail: am1proc@pscl.com



09/05/21

**(Md. Rafiquddaula)**

Manager (Procurement)  
Ashuganj Power Station Company Ltd.  
(An enterprise of Bangladesh Power  
Development Board)  
Ashuganj, Brahmanbaria, Bangladesh.  
E-mail: procurement@pscl.com